



Network Standard Advice

No. 1608A 22/03/2011

Doc. Ref. Network Standards: NS200

TO: Customers, Service Providers and Ausgrid Staff.

Amendments to Ausgrid's Network Standard NS 200, Major Substations Ventilation Design Standard, July 2010.

Introduction

This Network Standard Advice (NSA) amends Network Standard (NS) 200 Major Substations Ventilation Design Standard.

This amendment makes the following change.

- Replace the first paragraph of Clause 4.5 with;
Overpressure requirements, where applicable, shall be assessed separately from ventilation requirements. Where provision needs to be made for overpressure relief any openings that are provided for ventilation shall be included as part of the overpressure relief. NS 188 and NS 185 provide details of overpressure requirements for substations.

Note: Current network standards, with NSAs and CIAs, are available on Ausgrid's Internet site at www.ausgrid.com.au.

T. Lampard
Manager – Standards and Communications