
- Technology: Solar PV
 Maximum Power: 50 kW
- 3. Contribution to fault levels: N/A
- 4. Size & rating of the relevant Transformer: $N\!/\!A$
- 5. Single line diagram: refer to following page
 6. Protection Systems & Communication Systems: refer to following page
 7. Voltage Control and reactive power capability: N/A
 8. Details specific to the location of facility: N/A



| 1 | Under-voltage (UV): (27P) | 200V | 2 Sec | 1 | Vmax | 257V | TITLE | BACK-UP ANTI-ISLANDING PROTECTION OF A 50.0 KW | CUSTEMER |
|---|---|----------|------------|---|-----------------|--------|---------|--|------------|
| 2 | Over-voltage (OV) : (59P) | 270V | 2 Sec | 2 | Vmin | 200V | | GC SOLAR P∨ SYSTEM WITH MAINS PRO RELAY | |
| 3 | Under-frequency(UF):(81U) | 48 Hz | 2 Sec | 3 | Fmax | 52 Hz | | | P∨ ARRAY |
| 4 | Over-frequency (OF): (810) | 52 Hz | 2 Sec | | T III AX | | | | |
| 5 | Rate of change of Frequency (ROCOF) : (81R) |) 1 Hz/s | | 4 | Fmin | 48 Hz | | | DRAWING NO |
| 6 | Voltage Vector Shift (VVS): | 8° | Half Cycle | 5 | Disconnect Time | 2 Sec | COMPANY | NATURAL ENERGY ENGINEERS, | SCALE |
| 7 | Reconnection Time: 70 S | | | 6 | Reconnect Time | 60 Sec | | | DATE |
| | | | | | | | | | |

| 13/10/2015 | |
|------------|--|
| | |