



No.	DESCRIPTION	STOCK		QTY	
		AL	CU	ARR-1	ARR-2
1	CONDUCTOR - OVERHEAD	-	-	N/A	N/A
2	CONNECTOR - BARE MAINS/IPC	175051	H109694	2	2
3	HOOK - COACH SCREW M12x146	H75697	H75697	1	-
	HOOK - J SPIKE	1370	1370	-	1
4	LINK - WEAK CONNECTING 1.5kN	H81976	H81976	1	1
5	CLAMP - CABLE STRAIN 2-4 CORE 6-25mm ²	H102491	H102491	1	1
6	SERVICE CABLE - 4x25mm ² AL ABC, 4 CORE	H109280	H109280	A/R	A/R
7	END CAP - 25mm ² PUSH ON	H109447		1	1
8	CABLE TIE	TBA		1	1
9	CONNECTOR - SPLICE FOR NEUTRAL PHASE, BARE Al	182904	-	1	1
	CONNECTOR - SPLICE FOR NEUTRAL PHASE, BARE Cu	-	182905		



NOTE:
IPC CONNECTOR ORIENTATION IS DIAGRAMMATIC
ONLY, IT MAY BE INSTALLED IN ANY DIRECTION.

CAD DRAWING
DO NOT MANUALLY AMEND
AMENDMENTS
DWN: PATRICIA RIOS
CHKD: HIRI EHAMPARAM
DATE: 09/04/2014
NEUTRAL CONNECTION
CHANGED, MATERIAL
LIST AMENDED.
5
APPD: MATTHEW CUPPLES

NETWORK STANDARD
Ausgrid
145 NEWCASTLE RD
WALLSEND NSW 2287
PHONE: 4951 9388
FAX: 4591 9389

DESIGNED	ROBERT KNOWLES
DRAWN	PATRICIA RIOS
CHECKED	ROBERT KNOWLES
AUTHORISED	GREG SKINNER
DATE	02/07/04
SCALE	NTS
MAP REF.	
LGA	

STANDARD CONSTRUCTION
100AMP OPEN WIRE MAINS
SUPPORT FROM POLE - 2 PHASE

PROJECT No.	NET-STD
PROJTRAK No.	-
Sheet 01 of 1 Sheets	
A4	167459 5