



SECTION A-A
N.T.S.
ORIENTATION FOR
POLE STEP HOLES

TABLE 1.

LENGTH (m)	STRENGTH (kN)	STOCK CODE
17.00	6	H23559
17.00	8	H23567
17.00	12	157206
18.50	6	H23575
18.50	8	150490
18.50	12	152876
20.00	8	176343
20.00	12	150508
21.50	8	176344
21.50	12	150359

NOTES:
1. THE MINIMUM POLE EMBEDMENT DEPTH IS TO BE DESIGNED USING AUSGRID'S POLE EMBEDMENT CALCULATOR (PEC) AND COMPLY WITH THE REQUIREMENTS OF NS220.

**DRESSING FOR
6, 8 AND 12 kN POLES**

DIMENSIONS ARE IN MILLIMETRES UNLESS STATED OTHERWISE

CAD DRAWING DO NOT MANUALLY AMEND A M E N D M E N T S	DWN: PATRICIA RIOS
	CHKD: PHILLIP JONES
DATE: 19/11/2014	AUSGRID BORDER ADDED. STOCK CODES AMENDED.
APP'D by:	
DWN: P.R.	
CHKD: P.J.	
APP'D: G.F.	
DATE: 05/09/2024	NOTES ADDED. GENERAL AMENDMENTS

NETWORK STANDARD

145 NEWCASTLE RD WALLSEND,
NSW 2287

SCALE	1:25
DESIGNED	-
DRAWN	P.S
CHECKED	P.S
APPROVED	I.NICHOLS
DATE	20/08/1992
PROJECT NUMBER	STD
PROJTRAK NUMBER	-

STANDARD CONSTRUCTION DRESSING DETAILS FOR 17.0-21.5m TIMBER POLES			
SIZE	DRAWING No	SHEET	REV
A3	515279	1	8