

MIN. 88kN/m
WOVEN GEOTEXTILE

12mm ROADBASE OR
APPROVED EQUIVALENT
TYPE FCR 75mm THICK


75mm CLASS 1 FREE DRAINING
AGGREGATE 225mm THICK

TYPE B PAVEMENT
CBR 2% > 5%
UNREINFORCED 600mm THICK

CONSTRUCTION ISSUE

ALL DIMENSIONS IN mm UNLESS NOTED OTHERWISE

CAD DRAWING DO NOT MANUALLY AMEND	A M E N D M E N T S	
	0	INITIAL ISSUE
	1	DWN: PATRICIA RIOS CHKD: TAM NIVEN DATE: 09/03/2006 COVER CHANGED TO ROADBASE.
	2	AUTH'D: GLENN FORD DWN: PATRICIA RIOS CHKD: PHILLIP JONES DATE: 25/03/2009 NOTATIONS MODIFIED.
	APP'D: GLENN FORD	


EnergyAustralia
 DESIGN AND ENGINEERING BRANCH
 145 NEWCASTLE RD WALLSEND, NSW 2287
 TEL: 4951 9388 FAX: 4951 9389

SCALE	1:20
DESIGNED	TAM NIVEN
DRAWN	PATRICIA RIOS
CHECKED	TAM NIVEN
APPROVED	LUKE MURRAY
DATE	23/01/06
PRJTRK No.	-
PROJECT NUMBER	STD

STANDARD CONSTRUCTION ACCESS TRACK PAVEMENT CONSTRUCTION DETAILS TYPE B PAVEMENT			
DRAWING No	174293	SHEET	01
AMD	2	SIZE	A4