



228905_01R00

NOTE : TO BE HOT DIP GALVANISED
 ③ TO AS/NZ 4680:2006

REV	DATE	DETAILS OF REVISION	DRAWN	APPR
4	24-01-12	EARTHING STUD MOVED UPWARDS, WAS 75 mm FROM BOTTOM FACE.	SH	GA
3	21-04-11	GAL STD NOTE CHANGED & EX.NOTE ADDED	CJ	TS
2	03-09-10	WAS 60x50x2THK	PK	TS
1	30/03/05	PANEL FIXING & GAL NOTE ADDED	S.G.	S.J.

No. OFF	ITEM No.	DESCRIPTION	MAT'L/PRT.	LENGTH
1	5	PANEL FIXING	50x10 MS FL.	800
2	4	FIXING PIN	M16 ALLTHREAD	120
2	3	EARTH STUD	M10x35	SS
2	2	LOCATION LUG	6 MS PL	775 x 60
1	1	INFILL PANEL	3 MS PL	814 x 725

DIMENSIONS IN MILLIMETRES DRAFTING STANDARD AS1100		© THIS DRAWING IS THE PROPERTY OF SCHNEIDER PTY LTD		TRANSFORMER DIVISION BENALLA VIC. AUST.	
				COMMERCIAL IN CONFIDENCE	
DRAWN S.G. DATE 8-06-04		CHECKED S.J. DATE 8-06-04		APPROVED S.J. DATE 8-06-04	
		Schneider Electric		TITLE INFILL PANELS T2 CONCRETE BASE	
		P.O. No.		DRAWING No: 6675 465	
		SCALE		SHEET SIZE: A3	