



NOTE : TO BE HOT DIP GALVANISED TO AS/NZ 4680:2006³

1	5	PANEL FIXING	50x10 MS FL.	800
2	4	FIXING PIN	M16 ALLTHREAD	120
2	3	EARTH LUG	M10x35	SS
2	2	LOCATION LUG	6 MS PL	775 x 60
1	1	INFILL PANEL	3 MS PL	814 x 615

No. OFF	ITEM No.	DESCRIPTION	MAT'L/PRT.	LENGTH
---------	----------	-------------	------------	--------

DIMENSIONS IN MILLIMETRES
DRAFTING STANDARD AS1100

© THIS DRAWING IS THE PROPERTY OF SCHNEIDER PTY LTD

TRANSFORMER DIVISION BENALLA VIC. AUST.

COMMERCIAL IN CONFIDENCE

DRAWN S.G. DATE 8-06-04	CHECKED S.J. DATE 8-06-04	APPROVED S.J. DATE 8-06-04	TITLE INFILL PANELS T1 CONCRETE BASE
----------------------------------	------------------------------------	-------------------------------------	--

Schneider Electric

P.O. No. _____ DRAWING No: 6675 443

SCALE _____ SHEET SIZE: A3

REV	DATE	DETAILS OF REVISION	DRAWN	APPR
4	24-01-12	EARTHING STUD MOVED UPWARDS, WAS 75 mm FROM BOTTOM FACE.	SH	GA
3	21-04-11	GAL STD NOTE CHANGED & EX.NOTE ADDED	CJ	TS
2	03-09-10	WAS 60x50x2 THK	PK	TS
1	30/03/05	PANEL FIXING & GAL NOTE ADDED	S.G.	S.J.