



NOTES :

1. THE FOLLOWING INFORMATION IS OBTAINED FROM THE PROJECT DESIGN DRAWINGS :
 - a. POLE LENGTH AND STRENGTH.
 - b. SPECIAL FOUNDATION REQUIREMENTS.
 - c. POLE EMBEDMENT DEPTH.
 - d. PHASE CONDUCTOR AND OVERHEAD EARTHWIRE SIZE.
 - e. STAY REQUIREMENTS.
 - f. DEVIATION ANGLE.
 - g. ASSESSED EARTHING REQUIREMENTS.
2. THE MAXIMUM LINE DEVIATION ANGLE TO BE CONSTRUCTED ON THIS ARRANGEMENT IS TO BE DETERMINED BY THE LINE DESIGNER.
3. STAYS TO BE INSTALLED SO THAT THE STAYWIRE CLEARANCE FROM THE PHASE CONDUCTORS COMPLIES WITH THE STATUTORY REQUIREMENTS.
4. ONLY THE OPGW OVERHEAD EARTHWIRE OPTION IS SHOWN ON THIS CONSTRUCTION DRAWING.
5. USE THE OPGW SUSPENSION ARRANGEMENT WHEN ERECTING AN OPGW OVERHEAD EARTHWIRE. USE THE STANDARD EARTHWIRE SUSPENSION ARRANGEMENT WHEN ERECTING A NON OPGW OVERHEAD EARTHWIRE.
6. WHEN DESIGNING UNDERBUILT CIRCUITS ON A 33kV STRUCTURE, THE POSSIBLE USE OF LIVE LINE WORKING PROCEDURES MUST BE CONSIDERED WHEN NOMINATING THE CIRCUIT SEPARATION TO ALLOW A MINIMUM CLEARANCE OF 2500mm IF REQUIRED.
7. POLE STEPS SHOULD ONLY BE INSTALLED ON POLES WHERE ACCESS FOR NORMAL MAINTENANCE VEHICLES CANNOT BE MAINTAINED FOR THE LIFE OF THE POLE.

ITEM	DESCRIPTION	DRG.No.	QTY
6	STEP - POLE (SEE NOTE 7)	514084	A/R
5	EARTHWIRE - SUSPENSION, OVERHEAD, MOUNTING, ARRANGEMENT -1a (SEE NOTES 4 & 5)	514157	1
	OPGW - SUSPENSION, CONDUCTOR, MOUNTING, ARRANGEMENT -1a (SEE NOTES 4 & 5)	565744	
4	INSULATOR - HORIZONTAL LINE POST, 66kV, MOUNTING & BONDING, ARRANGEMENT -3a	514161	3
3	FOOTING - CONCRETE POLE, ARRANGEMENT (SEE NOTE 1)	512331	1
2	EARTHING - CONCRETE/STEEL, SINGLE POLE, BUTT, ARRANGEMENT	520209	1
1	POLE - CONCRETE (AS REQUIRED)		1

CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS	DWN: GARY HUGHES	APP'D by: GLENN FORD
	CHKD: GARRY CRAIG	
DATE: 15/10/2013	AUSGRID BORDER APPLIED.	
APP'D by: GLENN FORD	DWN: PATRICIA RIOS	APP'D by: GLENN FORD
CHKD: PHILLIP JONES	DATE: 31/03/2017	
HORIZONTAL LINE POSTS & OHEW CHANGED. NOTES & MATERIAL LIST AMENDED.		

NETWORK STANDARD

145 NEWCASTLE ROAD
WALLSEND NSW 2287

DESIGNED	PHIL JONES
DRAWN	PATRICIA RIOS
CHECKED	PHIL JONES
AUTHORISED	STEPHEN CONNOR
DATE	20/12/07
SCALE	1:25
MAP REF.	
LGA	
PROJECT No.	STD
PROJTRAK No.	STD

**STANDARD CONSTRUCTION
33kV VERTICAL HORIZONTAL
LINE POST CONSTRUCTION
WITH OVERHEAD EARTHWIRE
4-240 C/E**

SIZE	DRAWING No	SHEETS	AMD.
A3	185420	01 of 1	2