



REFERENCE DRAWINGS	
SUBURBAN SUBSTATIONS	
SUBURBAN SUBSTATIONS WITH E TYPE LV BOARD CABLING & SCHEDULES	A0-178231
SUBURBAN SUBSTATIONS WITH E TYPE LV BOARD AC & DC SCHEMATICS	B1-178232
WALL MOUNTED TRANSFORMER PROTECTION PANEL	B1-187815
WALL MOUNTED CUSTOMER OVERCURRENT PROTECTION PANEL	A0-118558
CITY SUBSTATIONS	
CITY BASEMENT SUBSTATIONS WITH E TYPE LV BOARD CABLING	B1-178233
CITY CONTROL POINT & UPPER LEVEL SUBSTATIONS WITH E TYPE LV BOARD CABLING	B1-178234
CITY SUBSTATIONS WITH E TYPE LV BOARD CABLE SCHEDULE	A1-178235
CITY SUBSTATIONS WITH E TYPE LV BOARD AC & DC SCHEMATICS	A0-178236
CITY SUBSTATIONS WALL MOUNTED TRANSFORMER PROTECTION PANEL	A0-115148
WALL MOUNTED CUSTOMER OVERCURRENT PROTECTION PANEL	A0-118558

CAD DRAWING DO NOT MANUALLY AMEND AMENDMENTS 2A CONNECTION WAS 2Z/OC. 2B CONNECTION WAS 2Z/OC. CUSTOMER SUPPLY ACB 2/COC-1a OR 2/COC-2a PN 208/6/9/2 PWJ 23.1.08 CHECKED: PIE APPROVED: PIE	2. CBD TRANSFORMER CONNECTIONS UPDATED TO LATEST MANUFACTURER'S DRAWING. CABLE CORE 1 CONNECTIONS CORRECTED IN SUBURBAN TRANSFORMER. INDIVIDUAL CABLE CONNECTIONS TO PROTECTION PANELS AND SIGNAL MARSHALLING BOX SHOWN. CABLE NUMBERS ADDED. REFERENCE DRAWING LIST REVISED. PN 208/6/9/2 PWJ 8.5.08.08 CHECKED: DRB APPROVED: PIE	3. WIRE 9x RELOCATED TO ADJACENT TERMINAL ON CBD TRANSFORMER CIRCUIT BREAKER. PN 02/2010/1/5/1 P.JARVIS 16.2.11 CHECKED: P.TURRIN APPROVED: P.TURRIN	4. NEW AUSGRID BORDER & LOGO ADDED. 30/09/2013 R.LAALAA T.LAMPARD APPROVED

<b>NETWORK STANDARD</b>  DISTRIBUTION OPERATIONS & RELIABILITY LOGISTICS & DISTRIBUTION ENGINEERING 25-27 POMEROY ST HOMEBUSH NSW 2140	SCALE	AS SHOWN
	DESIGNED	-
DRAWN	PWJ	
CHECKED	WJB	
APPROVED	PBH	
DATE	6/3/07	
PROJECT NUMBER	103/59/1/6	
PROJTRAK NUMBER	-	

<b>E TYPE LV BOARD          MERLIN GERIN MASTERPAC TP          AIR CIRCUIT BREAKERS          EXTERNAL CONNECTIONS</b>			
SIZE	DRAWING No	SHEET	AMD
A2	178237	1	4