



SUMMARY OF MASS:-		
TRANSFORMER OIL VOL.	821	Ltrs.
TRANSFORMER TOTAL	2688	kg.
ENCLOSURE	100	kg.
CHANNEL BASE	100	kg.
L.V. SWITCHGEAR	250	kg.
H.V. SWITCHGEAR	350	kg.
KIOSK TOTAL	3488	kg.
CONCRETE BASE	2000	kg.
TOTAL MASS	5488	kg.

PAINT  
 TRANSFORMER - STORM GREY N42  
 ENCLOSURE - RAIN FOREST GREEN G15

QTY.	ITEM	DESCRIPTION	PART NO.
1	36	VALVE BALL 32MM BORE LOCKABLE	VAL5081
1	35	T/C, ROTARY 33KV,9POS,60A, GAMEX	TCR060A9P3PH
1	34	BATTERY BOX	SCHNEIDER-BATTBOX
1	33	EARTH BAR LINK	S1B2305101
1	32	EARTH BAR LINK	S1B2305001
1	31	MAIN EARTH BAR	S1B2304901
1	30	FINAL ASSEMBLY OF CHANNEL BASE	S1B2068301
1	29	ENCLOSURE WALL	S1A9972901
1	28	DMA RM6 11KV 25KA/3S MOT P.SW	RM62N61XIQIEAMT101
1	27	POWERSENSE BOX	POWERSENSE
1	26	PLUG,GAL,FLG,DN32,M	PLG1362
1	25	HD SP BACK ENTRY PLUG 10A WHI	PDL905WH
1	24	BUSHING PAD RESIN 1700 AMP 380	PAD1000-1
1	23	LABEL - HIGH VOLTAGE	LAB5279
1	22	ENCL ASSY FIBREGLASS FOR L RANGE	KEAKLENC-BOL-V4
1	21	OIL PRESENCE INDICATOR	IND5026
1	20	EA Kiosk board KL 4/4/4/4+DMA	EZEA107_MIGXX
3	19	SURGE ARRESTOR AK POWER SOLUTIONS 5KA	BSH5122
3	18	BUSH WELL 33kv, 200 A, TO SUIT ELAST. K1501-A1	BSH2023
3	17	INSERT 22kv,200A, ELASTIMOLD K1501-A1	BSH1664
1	16	PRESSURE SWITCH COVER	BBV1737001_MIG26
1	15	UNISTRUT FOR HV CABLE SUPPORT	BAU1560201
2	14	WARNING LABEL - RM6	BAU1559301
1	13	BAFFLE BOTTOM HV	BAU1521901
1	12	RM6 RAISING PLINTH ASSLY - LH	BAU1513301
1	11	RM6 RAISING PLINTH ASSLY - RH	BAU1513201
1	10	CABLE TRAY - BATTERY MOUNTING PLATE ASSLY	BAU1202801
1	9	TERMINAL BOX - ASSLY	BAU1202701
1	8	PRESSURE SWITCH LABEL	AAV8357101_MIG26
1	7	PRESSURE SWITCH DISPLAY	AAV7454701_MIG26
1	6	RM6 SWITCHGEAR EXTENSION HANDLE	A048069
1	5	CONCRETE BASE	6675359C
1	4	TANK FINISH AUSGRID KL 800KVA	5505151601
1	3	NAME PLATE 800KVA 11/0.433kV Dyn1 +3 to -5 in 1.5% STEPS	4943263401
1	2	MASS PLATE KL 800 KVA	4942191701
2	1	SIGN DANGER-HIGH VOLT KEEP OUT	4942122-9

REFERENCE DRAWING LIST	
DESCRIPTION	DRAWING NUMBER
RM6 GA WITH WIRING DIAGRAM	S1B2134500
POWERSENSE	S1B2135000

REV	DATE	DETAILS OF REVISION	DRAWN	CHKD	APPR
03	20/10/15	ECN 1440: ISSUED FOR CONSTRUCTION. LV BOARD PART NOS. CHANGED FROM EAEA TO EZEA. Base 6675359C was 66753044	MJ	AS	TAS
02	08-01-15	DETAIL "B" ADDED, REFER SHEET 2/2. UPDATED DRG. ON CUSTOMER FEEDBACK. ECN# 1283.	DS	AS	TAS
01	13-11-14	MASS PLATE ADDED.	DS	MJ	TAS
00	15-10-13	RELEASED FOR MANUFACTURING	AA	SH	GA

Scale: 0.075  
 Tolerancing Standard: ISO 2768-1 cL  
 ISO 8015  
 Units of measure: millimeter

**Schneider Electric**

AUSGRID KL GENERIC GA FOR 800 KVA  
 CONTRACT # AG2869/11, ITEM # 18 TO 24.

Number: **EAV4813702**  
 Revision: **03**  
 Sheet: **1/2**

242583\_01r00